

# MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

# DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

Johns Manville Corporation 717 17th Street Denver, CO 80202

#### **SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION:** Johns Manville Modified Bitumen Roofing Systems over Poured Gypsum Deck.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 12-0203.05 and consists of pages 1 through 15. The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 1 of 15

## **ROOFING SYSTEM APPROVAL**

<u>Category:</u> Roofing

Sub-Category: Modified Bitumen

Materials:SBSDeck Type:GypsumMaximum Design Pressure:-75 psf.

# TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: TABLE 1

		Test	Product
<b>Product</b>	<b>Dimensions</b>	<b>Specification</b>	<b>Description</b>
DynaBase	54'-10" x 36"	ASTM D6163	An SBS modified bitumen coated, fiber
		Type I Grade S	glass reinforced base sheet.
DynaWeld Base	39'-3/8" x 32'-10"	ASTM D6163	An SBS modified bitumen coated,
		Type I Grade S	fiberglass reinforced base sheet for heat
			welded applications.
DynaGlas	39-3/8" x 32'-10"	ASTM D6163	An SBS modified bitumen membrane
		Type I Grade G	surfaced with granules for application in
			hot asphalt.
DynaWeld Cap FR	39'-3/8" x 32'-10"	ASTM D6163	A fire resistant SBS modified bitumen
		Type I Grade G	membrane surfaced with granules for
			heat weld applications.
DynaGlas 30 FR	39-3/8" x 32'-10"	ASTM D6163	A fire resistant SBS modified bitumen
		Type I Grade G	membrane surfaced with granules for
			application in hot asphalt.
DynaGlas FR	39-3/8" x 32'-10"	ASTM D6163	A fire resistant SBS modified bitumen
		Type I Grade G	membrane surfaced with granules for
			application in hot asphalt.
DynaKap T1	39-3/8" x 32'-10"	ASTM D6162	A fiberglass/polyester reinforced SBS
		Type I Grade G	modified bitumen membrane surfaced
			with granules for application in hot
			asphalt.
DynaKap FR T1	39-3/8" x 32'-10"	ASTM D6162	A fire resistant, fiberglass/ polyester
		Type I Grade G	reinforced SBS modified bitumen
			membrane surfaced with granules for
			application in hot asphalt.
DynaLastic 180	39-3/8" x 32'-10"	ASTM D6164	A 180 gram polyester mat reinforced
		Type I Grade G	SBS modified bitumen membrane
			surfaced with granules for application in
			hot asphalt.
DynaLastic 180 FR	39-3/8" x 32'-10"	ASTM D6164	A 180 gram polyester mat reinforced,
		Type I Grade S	granular-surfaced, modified bitumen cap
			sheet for use in fire-rated systems.
DynaLastic 180S	37" x 36'-9"	ASTM D6164	A 180 gram polyester mat reinforced,
		Type I Grade S	modified bitumen cap sheet for use in
			fire-rated systems.



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 2 of 15

		Test	Product
Product	<b>Dimensions</b>	<b>Specification</b>	<b>Description</b>
DynaPly T1	39-3/8" x 32'-10"	ASTM D6162	A polyester reinforced SBS modified
		Type II Grade S	bitumen ply sheet for use in
			conventional and modified bitumen
Demal actic 250	20.2/91 - 222 1022	ACTM DC164	built-up roof systems.
DynaLastic 250	39-3/8" x 32'-10"	ASTM D6164	A 250 gram polyester mat reinforced,
		Type II Grade G	granular-surfaced, modified bitumen cap sheet.
DynaLastic 250 FR	39-3/8" x 32'-10"	ASTM D6164	A 250 gram polyester mat reinforced,
DynaLastic 250 i ic	3) 3/0 K32 10	Type II Grade G	granular-surfaced, modified bitumen cap
		Type II Glade G	sheet for use in fire-rated systems.
DynaLastic 250 S	39-3/8" x 32'-10"	ASTM D6164	A 250 gram polyester reinforced, SBS
,		Type II Grade S	modified bitumen Base/Ply sheet for use as
			a base or ply sheet only.
DynaMax FR	39-3/8" x 32'-10"	ASTM D6162	A fire resistant, fiberglass/ polyester
		Type III Grade G	reinforced SBS modified bitumen
			membrane surfaced with granules for
D 01 1	20.2/01. 223 (2)	A CITE A D (200	application in hot asphalt.
DynaClad	39-3/8" x 33'-6"	ASTM D6298	A foil faced, glass reinforced, SBS
			modified membrane for application in hot asphalt.
DynaBase XT	39-3/8" x 49'-2"	ASTM D6163	A heavyweight glass reinforced SBS
Dynabase A1	39-3/0 A +9 -2	Type I Grade S	Base/Ply sheet.
DynaGlas FR XT	39-3/8" x 32'-10"	ASTM D6163	A heavyweight glass reinforced granular
D y in Gius I It III		Type I Grade S	surfaced SBS Cap sheet.
GlasKap	36" x 36'	ASTM D3909	A mineral surfaced, asphalt coated,
1			fiberglass cap sheet.
GlasKap CR	36" x 36'	<b>ASTM D3909</b>	A white mineral surfaced, white acrylic
			coated, fiberglass cap sheet.
Ventsulation Felt	36" x 36'	ASTM D4897	Heavy duty fiber glass base sheet
		Type II	impregnated and coated on both sides
			with asphalt with or without fine mineral
			stabilizer. Surfaced on the bottom side
			with coarse mineral granules embedded
Clas Daga Dhua	26" - 100'	A STM D4601	in asphaltic coating.
GlasBase Plus	36" x 108'	ASTM D4601	Type II asphalt impregnated and coated glass fiber base sheet for use in
			conventional and modified bitumen
			built-up roofing.
GlasPly IV	36" x 180'	ASTM D2178	Type IV asphalt impregnated glass felt
Glast ly 1 v	20 11 100	Type IV	for use in conventional and modified
		71	bitumen built-up roofing.
GlasPly Premier	36" x 180'	<b>ASTM D2178</b>	Type VI asphalt impregnated glass felt
		Type VI	for use in conventional and modified
			bitumen built-up roofing.
PermaPly 28	36" x 106'	ASTM D4601	Type II asphalt impregnated and coated
		Type II	glass fiber base sheet for use in
			conventional and modified bitumen
			built-up roofing.



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 3 of 15

D. J. A	D'	Test	Product
Product FesCant Plus Cant Strips, and Taper Edge	<u>Dimensions</u> various	Specification ASTM C728	<u>Description</u> Factory pre-fabricated cant strips and taper edge, manufactured from expanded perlite insulation.
MBR Flashing Cement Base and Activator	N/A	Proprietary	A two component elastomeric, cold application adhesive, consisting of a modified proprietary compound with an asphalt base.
MBR Bonding Cement and Activator	N/A	Proprietary	A two component, elastomeric, cold application adhesive.
Bestile Industrial Roof Cement	various	ASTM D4586 Type I	A trowel grade, cutback bitumen flashing grade cement mixture including inorganic fibers and mineral stabilizers.
Flex-I-Drain	various	BOCA 76-61 SBCCI 89204 UBC 3236	Two piece flexible drain system composed of a Noryl deck flange, a flexible neoprene bellows and no hub connection. Available in various sizes and styles for most retro-fit applications.
PC/PET RetroDrain	various	N/A	Engineered resin copolymer fabricated drain for retrofit applications.
USII RetroDrain	various	N/A	One piece, aluminum fabricated drain for retrofit applications.
SuperDome RetroDrain	various	N/A	Cast aluminum, heavy-duty drain for retrofit applications.
FP-10 Vents	10" deck flange, base diameter of 4" and a height of 6"	N/A	One-way roof vent, designed for use in various roof systems, for the release of pressure created by gases or moisture vapor trapped within the roofing system.
Expand-O-Guard	various	N/A	Elastomeric expansion joint cover for vertical expansion and seismic joints. Manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges.
Expand-O-Flash	various	N/A	Expansion joint covers manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges.
Presto-Lok Fascia and Flashing System	various	TAS 114	A multi-piece fascia and flashing system for built-up and modified bitumen roofing systems manufactured from aluminum or steel.
DynaTred & DynaTred Plus Roof Walkway	various	N/A	Preformed, skid-resistant boards.



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 4 of 15

## **APPROVED INSULATIONS:**

<b>TABLE</b>	2
--------------	---

	THEE =	
Product Name	<b>Product Description</b>	Manufacturer (With Current NOA)
ENRGY 3	Polyisocyanurate Insulation.	Johns Manville
Fesco Foam, DuraFoam	Polyisocyanurate Insulation with perlite facer	Johns Manville
Retro-Fit Board, DuraBoard	High-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Invinsa Roof Board	High density polyisocyanurate board	Johns Manville
DensDeck	Silicon treated gypsum	Georgia Pacific Gypsum, LLC
SECUROCK Gypsum-Fiber Roof Board	Rigid, gypsum-based board stock	USG Corp.

## **APPROVED FASTENERS:**

		TABLE 3		
Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Polymer Gyptec	Glass reinforced nylon gypsum & CWF decks fastener	Various	OMG
2.	Polymer Gyptec Metal Plate	Square galvalume AZ55 steel plate	3" square	OMG
3.	Polymer Auger Fastener	Glass reinforced Nylon insulation fastener for gypsum & CWF decks.	Various	Johns Manville
4.	Polymer Auger Plate	Round galvalume AZ55 steel plate	3" round	Johns Manville
5.	Nail-Tite Type (A or R) base ply Fasteners	Galvalume AZ55 base ply fastening systems for gypsum decks.	1.7" dia. Cap	ES Products, Inc.
6.	Twin Loc-Nail	Base sheet fastener with integrated Plate.	2.7" dia. plate	ES Products, Inc.
7.	Ultralok	Base sheet fastener with integral plate	2.7" dia. Plate	Johns Manville



NOA No.: 13-0129.17 **Expiration Date: 07/19/16** Approval Date: 06/27/13

Page 5 of 15

## **EVIDENCE SUBMITTED:**

Test Agency/Identifier Factory Mutual Research Corp.	<u>Name</u> 3001482	<u><b>Report</b></u> FM 4470	<u><b>Date</b></u> 08/11/98
ractory Mutual Research Corp.	3001482	FM 4470	09/10/98
	0Z8A9.AM	FM 4470	09/10/98
	3D4A4.AM	FM 4470	09/28/98
	3009499	FM 4470	04/04/01
	3012974	FM 4450	06/03/02
	3014090	FM 4470	09/05/02
	3001457	FM 4470	03/04/02
	3037222	FM 4470	10/02/09
	3026130	FM 4470	04/26/09
Dynatech Engineering, Inc.	4360.03.95-1	TAS 114	03/95
	4360.03.95-2	TAS 114	03/95
	4361.5.95-1	TAS 114	05/95
Underwriters Laboratories, Inc.	R10167	UL 790	05/27/13
Exterior Research & Design, LLC	#4361-2.04.97-1	TAS 114	04/28/97
	#4361-2.041	TAS 114	04/00/97
	10391.01.03	TAS 114	01/29/03
	#10390A-10.97-1	TAS 114	10/01/97
	#10390A-12.97-1	TAS 114	12/01/97
	00257.03.05-1	ASTM D6162/D6163	03/17/05
		ASTM D6164/D6298	
Trinity ERD	02843.02.07	TAS 114	02/07/07
111111)   2102	J7670.06.08	ASTM D3909	06/16/08
	J6990.12.07	ASTM D6162/D6164	12/03/07
	J13700.05.10-1-R1	ASTM D5147/D6163	01/25/11
	J13700.05.10-2	ASTM D5147/D6164	05/11/10
	J17040.11.09-R1	ASTM D6164	03/11/10
IRT-Arcon, Inc.	02-011	TAS 114	02/07/02
	02-026	TAS 114	07/26/02
PRI Construction Materials	JMC-066-02-01	ASTM D6163	06/04/12
Technologies, LLC	JMC-065-02-01	ASTM D6163	05/29/12
	JMC-070-02-01	ASTM D2178 Type IV	04/17/12
	JMC-071-02-01	ASTM D2178 Type VI	04/17/12
	JMC-072-02-01	ASTM D4601 Type II	06/14/12
	JMC-074-02-01	ASTM D4897 Type II	04/17/12
	JMC-075-02-04	ASTM D5147/D6164 Type II	08/03/12
	JMC-078-02-01	ASTM D5147/D6298	07/17/12
	JMC-081-02-01.02	TAS 117 B & C	06/11/12
	JMC-091-02-01 JMC-093-02-01	ASTM D4601 Type I ASTM D4601 Type II	06/04/12 08/02/12
	JMC-105-02-01	ASTM D4001 Type II ASTM D5147/D6162	05/02/12
	J1VIC-10J-02-01	Type III, Grade G	03/22/13
		Type III, Grade G	



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 6 of 15

## **APPROVED ASSEMBLIES**

**Membrane Type:** SBS

**Deck Type 6I**: Poured Gypsum, Insulated

**Deck Description:** Poured Gypsum Concrete

**System Type A:** Anchor sheet mechanically fastened; all layers of insulation fully adhered with

approved asphalt.

## All General and System limitations apply.

Anchor Sheet: One ply of PermaPly No. 28, DynaBase, DynaBase XT, DynaPly T1, GlasBase,

GlasBase Plus or Ventsulation fastened to the deck as described below:

Fastening #1: ES Products Nail-Tite Type A or Type R spaced 9" o.c. at the lap and in two rows

staggered 12" in the field of the sheet.

(Maximum Design Pressure -55 psf, See General Limitation #9)

Fastening #2: JM Ultralok or ES Products 1.8" Twin Loc-Nail spaced 9" o.c. at the 3" side lap

and two rows staggered 12" o.c. in the field.

(Maximum Design Pressure -75 psf, See General Limitation #7)

One or more layers of any of the following insulations:

<b>Base Insulation Layer</b>	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ENRGY 3	,	· ·
Minimum 1.4" thick	N/A	N/A
Fesco Foam, DuraFoam		
Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard		
Minimum ¾" thick	N/A	N/A
Retro-Fit Board		
Minimum ½" thick	N/A	N/A
Top Insulation Layer	<b>Insulation Fasteners</b>	Fastener
	(Table 3)	Density/ft <sup>2</sup>
Tapered Fesco Board, Tapered DuraBoard		
Minimum ¾" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 7 of 15 Ply Sheet: One or more plies of, GlasBase Plus, GlasPly Premier, GlasPly IV, DynaLastic

180 S, DynaBase, DynaBase XT or DynaPly T1 adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Membrane: One ply of, DynaKap T1, DynaKap FR T1, DynaMax FR, DynaGlas, DynaGlas

FR, DynaGlas 30 FR, DynaGlas FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly T1 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of

20-40 lbs./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR Adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-

40 lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400

lbs./sq., respectively.

Maximum Design

Pressure: See Fastening Options Above



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 8 of 15

**Deck Type 6I**: Poured Gypsum, Insulated

**Deck Description:** Poured Gypsum Concrete

**System Type B:** Base layers of insulation mechanically fastened, top layer fully adhered with

approved asphalt.

#### All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ENRGY 3 Minimum 1.3" thick	3 with 4 or 6	1:4 ft <sup>2</sup>
Fesco Board, DuraBoard Minimum 3/" thick	1 with 2. 3 with 4 or 6	1:2 ft²

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A
Retro-Fit Board Minimum ½" thick	N/A	N/A

Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, GlasPly Premier, GlasPly IV, DynaLastic 180

S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly T1 adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate

of 20-40 lbs./sq.



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13

Page 9 of 15

Membrane: One ply of DynaKap T1, DynaKap FR T1, DynaMax FR, DynaGlas, DynaGlas

FR, DynaGlas 30 FR, DynaGlas FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly T1 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of

20-40 lbs./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR Adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-

40 lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400

lbs./sq., respectively.

Maximum Design

Pressure: -55 psf. (See General Limitation #9).



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13

Page 10 of 15

Deck Type 6I: Poured Gypsum, Insulated

Deck Description: Poured Gypsum Concrete

**System Type C:** All layers of insulation simultaneously fastened.

All General and System limitations apply.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ENRGY 3	,	·
Minimum 1.3" thick	N/A	N/A
Fesco Board, DuraBoard		
Minimum ¾" thick	N/A	N/A
Retro-Fit Board		
Minimum ½" thick	N/A	N/A

Note: All layers shall be simultaneously mechanically fastened; see top layer below for fasteners and density.

Top Insulation Layer	<b>Insulation Fasteners</b>	<b>Fastener</b>
	(Table 3)	Density/ft <sup>2</sup>
Fesco Board, DuraBoard		
Minimum 3/4" thick	1 with 2, 3 with 4 or 6	1:2 ft <sup>2</sup>

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, GlasPly Premier, GlasPly IV, DynaLastic 180

S, DynaBase, DynaBase XT or DynaPly T1 adhered to the base sheet with

approved mopping of asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Membrane: One ply of DynaKap T1, DynaKap FR T1, DynaMax FR, DynaGlas, DynaGlas

FR, DynaGlas 30 FR, DynaGlas FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly T1 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of

20-40 lbs./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR Adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-

40 lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400

lbs./sq., respectively.

Maximum Design

Pressure: -55 psf. (See General Limitation #9).



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 11 of 15

**Deck Type 6I**: Poured Gypsum, Insulated **Deck Description:** Poured Gypsum Concrete

**System Type D:** All layers of insulation and base sheet simultaneously fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ENRGY 3		
Minimum 1.3" thick	N/A	N/A
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A
Retro-Fit Board Minimum ½" thick	N/A	N/A
DensDeck, SECUROCK Gypsum-Fiber Roof Board, Invinsa Minimum ¼" thick	Board N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of PermaPly 28, DynaBase, DyanBase XT, DynaPly T1, GlasBase Plus or

Ventsulation fastened to the deck as described below:

Fastening: Fasten base sheet with JM Polymer Auger or OMG Polymer Gyptec fasteners with

3" round plates spaced 9" o.c. at the lap and in two rows staggered 12" in the field

of the sheet.

Ply Sheet: (Optional) One or more plies of GlasBase Plus, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly T1 adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

Membrane: One ply of DynaKap T1, DynaKap FR T1, DynaMax FR, DynaGlas, DynaGlas

FR, DynaGlas 30 FR, DynaGlas FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly T1 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR Adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-

40 lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400

lbs./sq., respectively.

Maximum Design

Pressure: -55 psf. (See General Limitation #9).



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 12 of 15

Deck Type 6: Poured Gypsum, Non-Insulated

**Deck Description:** Poured Gypsum Concrete

Base sheet mechanically fastened. **System Type E(1):** 

All General and System Limitations apply.

Base Sheet: One ply of PermaPly No. 28, DynaBase, DynaBase XT, GlasBase Plus or

Ventsulation fastened to the deck as described below:

Attach base sheet with JM Ultralok or ES 1.8" Twin Loc-Nail or spaced 9" o.c. at Fastening:

the 3" side lap and two rows staggered 12" o.c. in the field.

Ply Sheet: (Optional) One or more plies of GlasBase Plus, GlasPly Premier, GlasPly IV,

> DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly T1 adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

Membrane: One ply of DynaClad, DynaKap T1, DynaKap FR T1, DynaMax FR, DynaGlas,

> DynaGlas FR, DynaGlas 30 FR, DynaGlas FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly T1 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of

1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR Adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-

40 lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400

lbs./sq., respectively.

Maximum Design

Pressure: -75 psf. (See General Limitations #7).



NOA No.: 13-0129.17 **Expiration Date: 07/19/16** Approval Date: 06/27/13

Page 13 of 15

**Deck Type 6**: Poured Gypsum, Non-Insulated

**Deck Description:** Poured Gypsum Concrete

**System Type E(2):** Base sheet mechanically fastened.

All General and System limitations apply.

Base Sheet: One ply of PermaPly No. 28, DynaBase, DyanBase XT, DynaPly T1, GlasBase

Plus or Ventsulation fastened to the deck as described below:

Fastening: ES Nail-Tite Type 'A' or Type 'R' fasteners spaced 9" o.c. at the lap and in two

rows staggered 12" o.c. in the field.

Ply Sheet: (Optional) One or more plies of PermaPly R, GlasBase, GlasBase Plus, GlasPly

Premier, GlasPly IV, DynaBase, DynaBase XT or DynaPly T1 adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5

gal./sq.

Membrane: One ply of DynaKap T1, DynaKap FR T1, DynaMax FR, DynaGlas, DynaGlas

FR, DynaGlas 30 FR, DynaGlas FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly T1 adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap Adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400

lbs./sq., respectively.

Maximum Design

Pressure: -55 psf. (See General Limitation #9).



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13

Page 14 of 15

#### **GENERAL LIMITATIONS:**

- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
- 3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
- 4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

### Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

- 5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
- 6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
- 7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
- 8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
- 9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)
- 10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE



NOA No.: 13-0129.17 Expiration Date: 07/19/16 Approval Date: 06/27/13 Page 15 of 15